

Fedex 7797 5073 4942

**STATE OF FLORIDA  
DEPARTMENT OF HEALTH**

**OFFICIAL NOTICE TO ABATE A SANITARY NUISANCE**

Authority: Chapter 381 & 386, F.S.

TO: [REDACTED]  
[REDACTED]  
Lehigh Acres, FL 33974

Registered Agent For: Lee Boulevard Baptist Church of Lehigh Acres, Inc.  
3107 Lee Blvd.  
Lehigh Acres, FL 33971

Complaint No. 36-99-430419

You are hereby directed to abate a sanitary nuisance existing on the property under your control at 3107 Lee Blvd., Lehigh Acres, FL 33971 in the county of LEE, State of Florida, contrary to the Laws of the State of Florida and which subject the offender to a penalty for failure to remove or abate the below described nuisance.

An Inspection on 11/01/2024 disclosed a commercial institution increasing the total estimated sewage flow from 585 Gallons Per Day to 1,650 Gallons Per Day. This increase in total estimated sewage flow requires the existing septic system to be brought into compliance based on the new total estimated sewage flow. These conditions directly violate Chapter No. 381 & 386 of the Florida Statutes and Chapter 62-6 of the Florida Administrative Code: Improperly modified and maintained septic system.

Served By:

By the Direction of: Jennifer Roth

Name: Connor Biro

Title: Environmental Specialist III

Telephone No.: 239-690-2100

Copy Provided To: Issued upon Property Owner: Lee Boulevard Baptist Church of Lehigh Acres, Inc. of 3107 Lee Blvd., Lehigh Acres, FL 33971 on the 4<sup>th</sup> day of November, AD, 2024, at 12:00 o'clock PM., by delivering a true copy hereof.

Note: Serving may be accomplished by personal delivery, certified mail to last known address or by attachment to occupied office or residence.

Connor Biro of Lee County Health Department

(See page 2 for corrective actions needed to be taken)

You are hereby directed to remedy this condition by following these corrective actions:

**Option A:**

1. Immediately cease & desist use of the septic system with the unapproved total estimated sewage flow.
2. Apply for an engineer-designed modification permit with the Florida Department of Health in Lee County within 30 days receipt of this notice.
3. Have the septic system repaired in accordance with the issued modification permit before permit expiration.
4. Maintain sanitary conditions at all times and notify this department of any actions taken to remedy this issue.

**Option B:**

1. Immediately cease & desist use of the septic system with the unapproved total estimated sewage flow.
2. Apply for a sewer connection with the Florida Governmental Utility Authority within 5 days receipt of this notice.
3. Once the connection has been established, apply for an abandonment permit with the Florida Department of Health in Lee County.
4. Once the abandonment permit has been issued, have the septic tank pumped and properly abandoned before permit expiration.
5. Maintain sanitary conditions at all times and notify this department of any actions taken to remedy this issue.